

TOWN OF KINGSTON SPRINGS SEWER DEPARTMENT REPORT

4/11/08

During the recent heavy rains the sewer system did very well. We did experience several pump failures due to increased run time.

One lift station was struck by lightning and was repaired.

All lift stations are running well at this time.

Eight septic tanks were pumped this month.

I attended a seminar on wastewater treatment and collection systems, in Dickson for continuing education credit. These meetings are very beneficial in keeping the sewer operator informed on new technology and rules.

The Wastewater Plant is operating at 90% efficiency at this time.

Robert Gupton
Public Works Director